

DEPARTMENT OF TRANSPORTATION

ESC/OE MS #43
1727 30TH Street, 2ND Floor
Sacramento, CA 95816



November 30, 2000

07-LA-710-10.7/15.5
07-1384U4
ACNH-P710(003)E

Addendum No. 3

Dear Contractor:

This addendum is being issued to the contract for construction on State highway in LOS ANGELES COUNTY IN LONG BEACH FROM ROUTE 1 TO ROUTE 405/710 SEPARATION.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on December 7, 2000.

This addendum is being issued to revise the Notice to Contractors and Special Provisions.

In the Special Provisions, Section 10-1.32, "RUBBERIZED ASPHALT CONCRETE (TYPE G)," subsection "GENERAL," the fourth paragraph is revised as follows:

"The asphalt-rubber binder content of the rubberized asphalt concrete (Type G) will be determined by extraction tests in conformance with the requirements in California Test 382."

In the Special Provisions, Section 10-1.33, "RUBBERIZED ASPHALT CONCRETE (TYPE O)," subsection "GENERAL," the third paragraph is revised as follows:

"The asphalt-rubber binder content of the rubberized asphalt concrete (Type O) will be determined by extraction tests in conformance with the requirements in California Test 382."

In the Special Provisions, Section 39-5.03, "VERIFICATION," in Table 39-6, "ALLOWABLE TESTING DIFFERENCE," Test Method CT 379 for asphalt content is deleted.

In the Special Provisions, Section 39-11.02, "STATISTICAL EVALUATION AND DETERMINATION OF PAY FACTOR," in Table 39-9, "MINIMUM QUALITY CONTROL REQUIREMENTS," Test Method CT 379 for asphalt content is deleted.

To Proposal and Contract book holders:

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.

Submit bids in the Proposal and Contract book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

Addendum No. 3
Page 2
November 30, 2000

07-LA-710-10.7/15.5
07-1384U4
ACNH-P710(003)E

This office is sending this addendum by confirmed facsimile to all book holders to ensure that each receives it.

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

NICK YAMBAO, Chief
Office of Plans, Specifications & Estimates
Division of Office Engineer